



SELCO Foundation – Call for Vendors

The Supply, Installation and Commissioning & Comprehensive maintenance of Solar Photovoltaic (SPV) Off-grid Systems.

SELCO Foundation – Procurement Officer
690, 15th Cross Rd, Jeewan Griha Colony, 2nd Phase,
J P Nagar, Bengaluru, Karnataka 560078
procurement@selcofoundation.org

SELCO Foundation hereby invites bids for the Supply, Installation and Commissioning & Comprehensive maintenance of Solar Photovoltaic (SPV) off-grid systems for 5 years – 28 Primary/Higher Primary Schools across the state of Maharashtra & Karnataka during the year 2024-2025.

The detailed tender document which can be downloaded from 11-12-2024.

<https://selcofoundation.org/tender/>

Bids, as per the terms and conditions herein should be submitted preferably through the online form (E-tender)

<https://forms.gle/ZRk7c2j5wEEfVAj78>

or submitted to the undersigned, at the above-mentioned address

by 4 pm on or before 18-12-2024.

Chief Executive Officer – SELCO Foundation



SELCO FOUNDATION

TENDER NOTIFICATION

FOR

**SUPPLY, INSTALLATION AND COMMISSIONING & COMPREHENSIVE
MAINTENANCE OF SOLAR PHOTOVOLTAIC (SPV) OFF-GRID SYSTEMS
FOR 5 YEARS – 28 PRIMARY/HIGHER PRIMARY SCHOOLS ACROSS
THE STATE OF MAHARASHTRA & KARNATAKA DURING THE YEAR
2024-2025.**

TENDER DOCUMENT

Address for Communication

SELCO Foundation
#690, 15th Cross Rd, J P Nagar – 2nd Phase
Bangalore, Karnataka – 560078
Telephone: 080-26493145
E-mail: procurement@selcofoundation.org

DISCLAIMER

NIT (Notice Inviting Tender) No: 11/2024-2025

This tender by SELCO Foundation is for selection of vendors (hereinafter “Organisations” or “Bidder”) for the work of Supply, Installation, and maintenance (including training) for 5 Years – 28 Primary/Higher Primary Schools across the state of Maharashtra & Karnataka during the year 2024-2025.

NOTE:

1. Though adequate care has been taken while preparing the Notice Inviting Tender (NIT) document, each Organization shall satisfy themselves that the document is complete in all respects. Intimation of any discrepancy shall be given to the Procurement Team at procurement@selcofoundation.org. If no intimation is received from any Organizations within five (05) days from the date of notification of Request for solution (RFS)/ Issue of the RFS documents, it shall be considered that the RFS document is complete in all respects and has been received by the Organizations.
2. SELCO Foundation has the right to award the works under this tender to single or multiple Organizations and in multiple tranches based on the best technical specifications and lowest quote ascertained through this tender.
3. The implementation of Solar Solutions at the said Schools is subject to receiving the approval for installation from the local School authorities.
4. SELCO Foundation reserves the right to cancel/withdraw this invitation for bids without assigning any reason and shall bear no liability whatsoever consequent upon such a decision
5. SELCO Foundation reserves the right to modify, amend or supplement this document.
6. While this RFS has been prepared in good faith, neither SELCO Foundation nor their employees or advisors make any representation or warranty, express or implied, or accept any responsibility or liability, whatsoever, in respect of any statements or omissions herein, or the accuracy, completeness or reliability of the information, and shall incur no liability under any law, statute, rules or regulations as to the accuracy, reliability or completeness of this RFS, even if any loss or damage is caused by any act or omission on their part.

CONTENTS OF BID DOCUMENT

Section No.	Description	Page No.
Section 1	Bid Invitation	5
Section 2	Instruction to Organizations	6-14
Annexure - 1	Solar Design	15-24
Annexure - 2	Technical Specifications	25-40
Annexure - 3	List of Schools	41

1. List of Documents to be Submitted in First Cover (In Technical bid)

Table	Description	Page No.
Annexure - 4	Confirmation on Components	42-46
Annexure - 5	Details of Organization	47
Annexure - 6	Check list of documents to be submitted in first cover	48

2. List of Documents to be Submitted in Second Cover (In Financial bid)

Table	Description	Page No.
Annexure - 7	Schedule of Tender	49
Annexure - 8	Price Schedule	50
	Conditions	51

SELCO FOUNDATION
#690 15th Cross J P Nagar 2nd Phase
Bangalore - 560078
Telephone: 080-26493145
E-mail: procurement@selcofoundation.org

Tender: **11/2024-2025**

Dated: 11-12-2024

NOTICE INVITATION TENDER

Chief Executive Officer of SELCO Foundation, Karnataka State, India hereby invites bids for Supply, Installation and Commissioning & Comprehensive maintenance of Solar Photovoltaic (SPV) off-grid systems for 5 years– 28 Primary/Higher Primary Schools across state of Maharashtra and Karnataka.

1.	Tender Ref No.	11/2024-2025
2.	Last date & time for the bid submission	18-12-2024, 5:00 PM
3.	Opening date of Technical Bid & Financial Bid	19-12-2024, 11:00 AM
4.	Venue of acceptance and opening of tenders.	SELCO Foundation, Bangalore
5.	Link for e-tender	https://forms.gle/ZRk7c2j5wEEfVAj78

Interested and eligible Organizations may furnish the Technical & Commercial Bids for Supply, Installation and Commissioning & Comprehensive maintenance of Solar Photovoltaic (SPV) off-grid systems for 5 years- 28 Primary/Higher Primary Schools across the state of Maharashtra & Karnataka.

<https://forms.gle/ZRk7c2j5wEEfVAj78>

Or;

Furnish the same to the below-mentioned address:

Procurement Officer - Tender NO 11/2024-2025
#690 15th Cross J P Nagar 2nd Phase
Bangalore - 560078
Telephone: 080-26493145

Any further information or clarification may obtain either in person or through phone during office hours from the office of the SELCO Foundation Ph: 080-2649 3145 or through the email – procurement@selcofoundation.org

sd/-
Chief Executive Officer
SELCO Foundation

INSTRUCTION TO ORGANIZATION

Schedule of Supply, installation, and commissioning:

Bidder must confirm the schedule of supply, installation and commissioning which is indicated below and the same has to be confirmed through duly enclosing "[Annexure 7](#)".

Sl. No.	Scheduled activity	Within days (no. of days)
1.	Supply starts	15 days
2.	Supply ends	25 days
3	Installations begins	10 days
4.	Commissioning of all the system	30 days

Note: Equipment supply can start individually and earlier than scheduled deadline. Grouting the array mount, earthing pit, and Lightning arrester work can start as early as possible. So that installation and commissioning time schedule is reduced and closure of the tender is on time. The Bidder shall complete the supply schedule as per "[Annexure 7](#)" enclosed in this Bidding Documents. If the bidders wish to visit the site, they may request the same to the Procurement Officer - Selco Foundation.

1. Eligibility to Organizations:

- I. The organization should be in operation for the last Five (05) years in the field of supply, installation and maintenance of Solar Energy Solutions.
- II. Organization registration certificates or any other proof of incorporation to be submitted to establish the legal status.
- III. The organization should be able to provide excellent service. Complaints on the system should be attended within 03 days and should be resolved within 10 working days of reporting.
- IV. The organization should have its own local office, service centre and technicians in the state of Maharashtra and Karnataka.
- V. Solar panels used by the organization should be of a supplier in India and should have manufacturer valid license and evidence for the same has to be provided.
- VI. Audited Financial Statements Certified by Auditor for the last 02 years.
- VII. Income Tax returns for the last 02 financial years should be submitted.
- VIII. Organization should submit the valid PAN card & Bank Details.
- IX. The organization should submit the self-declaration certificate to declare that the organization is not blacklisted by any entity.
- X. Documents to establish that the organization has implemented projects of worth Rs. 01 crores or more in the last financial year. In case of organizations not meeting this requirement of implementing projects worth of Rs. 01 crores in the previous financial year, SELCO Foundation may decide to give a portion of the order to such entities subject to the fact that all other criteria are met. The decision of SELCO Foundation in this regard will be final and binding on such a bidder.
- XI. The quote should include AMC (ANNUAL MAINTENANCE CONTRACT) for 5 years with a minimum of 2 scheduled services in a year.

2. Cost of bidding:

The Organizations shall bear all costs associated with the preparation and submission of Bid to the Chief Executive Officer, SELCO Foundation (hereinafter referred to as "the Foundation"). The Foundation will in no case be responsible or liable for these costs, regardless of the conduct or outcome of the bidding process.

The technical proposal shall contain:

- I. Confirmation on Components as per [Annexure - 4](#)
- II. Particulars of the Firm as per [Annexure - 5](#)
- III. Checklist of Documents to be submitted in First cover as per [Annexure - 6](#)
- IV. The Organizations has to submit an acceptance letter of guarantee for 5 years for the total performance of the Solar Energy Systems
- V. The bidder should have a service center facility in Maharashtra and Karnataka State.
- VI. The Organizations have to sign all the pages of the documents as acceptance of all terms and conditions.

3. The financial bid shall contain:

The rate quoted for Solar Energy Solutions in different geographies. The rate quoted should include all taxes levied by the State & Central Govt. Packing, and forwarding charges including transportation, loading & unloading, installation & commissioning and annual maintenance.

4. Price schedule:

The Organizations shall complete the price schedule as per [Annexure 8 - PRICE SCHEDULE](#) furnished in the Bidding Documents, indicating the total cost towards supply, installation and AMC. The SELCO Foundation will not pay any extra charges over and above the rate quoted by the Organizations. SELCO Foundation will only accept the budget in the exact format outlined in [Annexure 8](#).

5. Fixed price:

Prices quoted by the Organizations are firm and final and binding and not subject to variation on any account. A bid submitted with an adjustable price quotation will be treated as non-responsive and rejected.

6. Period of Validity of Bids:

Bids shall remain valid for a period of 12 months from the date of opening of the Second cover (Financial Bid). A Bid valid for a shorter period shall be rejected by the Foundation as non-responsive.

7. Format and Signing of Bid:

The Organizations shall give a set of hard copies of all the documents on the sealed cover. The Bids could be submitted preferably through the online form (E-tender)

<https://forms.gle/ZRk7c2j5wEEfVAj78>

or submitted by hand or post/courier to the below-mentioned address

Procurement Officer - Tender No 11/2024-2025
SELCO Foundation, #690, 15th Cross, 2nd Phase,
JP Nagar, Bengaluru- 560078.
Email id: procurement@selcofoundation.org

Deadline for Submission of Bids:

Bids must be received by the Foundation no later than the time and date specified in the **Invitation for Bids**. The Foundation may, at its discretion, extend this deadline for submission of the bid by amending the bid Documents in which case all rights and obligations of the Foundation and Organizations previously subject to the deadline will thereafter be subject to the deadline as extended.

8. Tender Opening:

The Technical & Financial bids will be opened separately as per the date and time mentioned above. The Financial bids (Second Cover), of only technically qualified Organizations, will be opened. The Organizations Names, Bid Modifications, or Withdrawals, bid prices, Discounts and the presence or absence of the requisite details as the Foundation, at its discretion, may consider appropriate will be recorded by the Purchasing Committee of SELCO Foundation. No Bid shall be rejected at bid opening, except for late bids, which will be rejected.

9. Clarification of Bids:

During evaluation of Bids, SELCO Foundation may, at its discretion, ask the Bidder for a clarification of its bid. The request for clarification and the response shall be in writing only.

10. Preliminary Examination:

The Foundation will examine the Bids to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed, and whether the bids are generally in order.

Arithmetical errors will be rectified on the following basis. If there is a discrepancy between words and figures, the lowest of the two shall prevail and the bid shall stand corrected to that effect. The Foundation may waive any minor infirmity or non-conformity or irregularity in a bid, which does not constitute a material deviation, provided such a waiver does not prejudice or affect the relative ranking of any Organizations.

11. Acceptance or rejection of bids:

CEO, SELCO Foundation reserves the right to accept or reject any bid and to annul the bidding process and reject all bids at any time prior to award of contract, without thereby incurring any liability or any obligation to inform the affected Organizations or Organizations of the grounds for the said action.

Any Bid with incomplete information is liable to be rejected.

12. Selection of Technical Specifications, Decision on quality:

The rights of selection of technical design/ specifications and evaluation of the quality of products will be done by a team of technical experts appointed by the Procurement Committee of SELCO Foundation and their decision will be final and binding.

Bidders must submit technical information in accordance with [Annexure 4](#) for their bid to be accepted. Submissions that are missing/incomplete information or have blank fields will not be considered.

Eligible bidder may be required to coordinate site visits for the SELCO Foundation Technical Team to evaluate the quality of the previous installation. This team will then generate a report detailing their findings and observations. The eligible bidders shall comply and facilitate such visit, in accordance with SELCO Foundation's requirements as communicated. This report will be taken into consideration by SELCO Foundation before awarding the tender.

13. Awarding Tender

The Tender will be awarded based on the criteria as stated in the Tender and in accordance with SELCO's policies. The bidder who has provided all documents in compliance with the terms and

regulations stated under this Tender and have further complied with SELCO's terms (as clarification would be required from time to time) will be awarded the tender.

The award for this tender will be communicated to the successful bidder by email.

SELCO shall have the right to disqualify an eligible bidder at its own discretion.

14. Terms and Conditions of the Contract

14.1 Duration: The agreement will be valid from the date of signing the Contract and for a period 5 years (60 months) from the date of completion of the supply, installation, commissioning of Solar Photovoltaic (SPV) off-grid systems. The maintenance and service will commence from the date of completion of installation of the solar system and will be effective for a period of 5 (five) years. The end date of this agreement will be sixty (60) months after the date mentioned in supply, installation and commissioning reports that will be subsequently annexed to this agreement and will form an integral part of this agreement.

14.2 Prices: Prices provided by the Bidder, and accepted by the Foundation shall be considered as final and firm and will not be subject to escalation due to any variations in the prices of materials, labour and/or any other reasons which may occur while the order is being carried out (except any increase in costs due to a change in applicable taxes). The Project Costs are inclusive of taxes, transport, installation and 5 year maintenance service which will include minimum two visits to the sites per year. The costs mentioned here do not include replacement of spares while servicing.

14.3 Payment Terms: For the supply, installation, commissioning, and comprehensive maintenance of Solar Photovoltaic (SPV) off-grid systems payment will be released in 02 tranches under each contract by SELCO Foundation.

- a. The 1st tranche of payment will be 50% paid along with the work order and against submission of invoice, delivery & installation schedule.
- b. The 2nd and final tranche of payment will be 50% and will be paid on receipt of Installation Report along with Photographs of Installations by location wise/system wise duly certified by school authority and Foundation representative Officer and against submission of invoice. Along with receipt of hand over letter (in SELCO Foundation Letterhead) to the school authority and the Organization shall furnish a bank guarantee valid for the term of this Agreement, i.e., 5 years for a total AMC cost or 5% of the project cost whichever is higher, before the release of final payment tranche towards the service and maintenance of Solar Energy Solutions (Bank guarantee format to be verified by SELCO Foundation).
- c. Any taxes and charges such as TDS that will have to be deducted from the WO amount as per the rules in force at the time of release of payment will be done by the SELCO Foundation and the Bidder will be paid only the net amount.
- d. The Bidder should submit the progress report to the Senior Program Manager, SELCO Foundation who will approve the invoice for payments based on the project performance and stages of completion.
- e. The Bidder has to provide installation certificate for each location mentioning the date of commissioning make & serial no. of each material (Solar panels, PCU, Battery etc.), and Photographs of the system installed before disbursement of the final instalment.
- f. The organization shall maintain sufficient (10% of total systems supplied) spare parts (Shall include all possible spares that can go faulty) of critical components for a period of 5 years like, earthing cables and pipes, lighting arrestor, SPD, MCB, fuses, cables and lugs, SMPS board, IGBT, Mother board, distilled water, petroleum jelly, battery caps, inverter

display board, static board, 4 modular board, inverter fan relay, AJB I/O connectors, etc locally within the interventional state to ease the service in a minimal downtime.

Note: For every tranche of payment, bidder has to raise an invoice

14.4 Insurance:

- a. Required insurance shall be arranged and maintained by the Bidder till the products/components are delivered in full to the end point and installation is completed.
- b. Material safety after delivery: Arrangement of transport, warehouse for stocking and safekeeping of the material till the handover is within the bidder's scope of work and SELCO Foundation will not be responsible for any missing item or damage that is incurred before the system is handed over to the School authority.
- c. Accidental damage for supplied items or to delivery staff or installation staff is the responsibility of the bidder and the bidder will ensure required insurance coverage and damage to service staff in case of any accidents during the course of this engagement with SELCO Foundation for providing the services covered under this agreement.

14.5 Inspection, Checking, Testing:

The products covered by the Work order shall be subject to inspection within a reasonable time after arrival at the place of delivery and the bidder must facilitate this process by fixing time informing SELCO Foundation in writing in advance and making bidder representative available at the location. Besides, the SELCO Foundation is also entitled to do a preliminary inspection at the manufacturing site of the Bidder by giving prior notice.

The Bidder shall provide free access to the SELCO Foundation during normal working hours at Bidder's or its sub-Bidder's works and place at their disposal, internal test reports, material/component test certificates and approved drawings. Even if inspections and tests are fully carried out, Bidder shall not be absolved to any degree from their responsibilities to ensure that products supplied, comply strictly with requirements of the Work order and technical specification at the time of delivery, inspection on arrival at site, installation and commissioning and warranty/guarantee period.

In any case, the products supplied must be strictly in accordance with the Work order and the technical specification specified by the tender failing which the Foundation shall have the right to reject goods and hold the Bidder liable for non-performance of contract.

14.6 Packing:

Bidder is fully responsible for adequately packing products/components mandated in the tender and ensuring appropriate packing suitable for inland carriage and ensuring complete safety of goods from any kind of damage during transport and subsequent storage at the Heath Centre authority.

14.7 Assembly, Pre-installation survey, Installation, after sales service and training:

- a. The Bidder shall be fully responsible for the assembly of the product at the destination site and completeness of the Project as per the Work order.
- b. The successful bidder must carry out a pre installation survey at his own cost so that the bidder will have a clear idea on logistics to reach materials, estimating the ease of material movements, pre installation preparations etc.

- c. The bidder must ensure proper insulators, appropriate height and necessary grout for lightning arresters up to grounding. Any deviation has to be brought to the notice of the SELCO Foundation and written/ email acceptance must be availed before adopting the deviation.
- d. The Bidder shall be fully responsible for getting the materials for grouting/preparation for foundation wherever required, curing of the grouting before installing. Bidder cannot hand over this part of the work to an unskilled labourer or person in charge at the School.
- e. Bidder should provide training on basic maintenance of the solar system to the designated School staff.
- f. Danger Boards should be provided as and where necessary as per Indian Electricity Act, 2003 and Rules, posters for DOs and DON'Ts need to be provided. At array, battery bank, distribution box, Inverter/PCU etc.
- g. The Bidder shall provide necessary "After Sales Service" at site for a period of 5 years. Bidder must keep a log book at each site /to be maintained at each system location and the bidder representative must record the service done/complaint recorded /resolution done /instructions if any.
- h. Bidder is solely responsible for any type of complaints to the supplied system and complaints have to be resolved within 5 to 10 working days after lodging.
- i. Complaints will be lodged using SMS/WhatsApp messenger app/email or a phone call and the bidder must provide the appropriate active contacts like phone number/email ID/WhatsApp number for lodging complaints.
- j. Active contact numbers will be displayed at the site prominently for registering any complaints on the performance of the product.

14.8 Delivery terms:

- a. Successful bidder will be provided a detailed written communication on site address, system to be installed and a brief site profile for installation and necessary contacts.
- b. The delivery of the said products will be to the school authority as per the list provided by the SELCO Foundation in writing. No variation shall be permitted, except with prior authorization in writing from the SELCO Foundation.
- c. Delivery Schedule and terms will be as per the WO. In case of a delay solely attributed to the bidder in meeting the said deliverables, the Bidder shall be liable to pay a late fee at the rate of 2% per week beyond a period of 30 days and up to a maximum of 10% of the value of this Agreement.

14.9 Risk Purchase on Default:

In case of default on the part of the Bidder to supply all the products or part thereof covered by the contract as per the standard/specifications within the contractual delivery period stipulated in the contract, the SELCO Foundation shall have the right to purchase such products or other of similar description at the risk and cost of the Bidder. Bidder shall be liable to pay the cost of such purchase products and also the penalty under clause 8 above for resultant delay.

14.10 Delay due to force majeure:

If any time during the continuance of the Agreement the performance in whole or part by either party on any obligation under the contract shall be prevented or delayed by reason of any war, hostility, explosions, epidemics, quarantine restrictions, or other acts of God, then provided, notice of the happening of any such event is given by either party to the other within fifteen (15)

days from the date of occurrence thereof. Either party shall be entitled to terminate this contract if such Force Majeure event persists for a period of ninety days and neither party has any claim for damages against the other in respect of such non-performance and delay in performance and deliveries under the contract. All duties and responsibilities of the Parties shall be resumed as soon as practicable after such event has come to an end or ceased to exist. Force Majeure conditions shall not affect the payment obligations of the SELCO Foundation which shall be made as per clause 3 of this Agreement.

14.11 Rejection, Removal of Rejected Goods and Replacement:

In case the testing and inspection at any stage by inspectors reveal that the product, material and workmanship do not comply with the agreed specifications and requirements, the same shall be removed by the Bidder at his/its own expenses and risk within 15 to 20 working days of written information of rejection by the SELCO Foundation. The SELCO Foundation shall be at liberty to dispose of such rejected goods in such manner as they may think appropriate, in the event the Bidder fails to remove the rejected goods within the period as aforesaid. All expenses incurred by the SELCO Foundation for such disposal shall be payable by the account of the Bidder. The freight paid by the SELCO Foundation, if any, on the inward journey of the rejected material shall be reimbursed by the Bidder to the SELCO Foundation before the rejected materials are removed by the Bidder. The Bidder will have to proceed with the replacement of that product or part of the product without claiming any extra payment if so, required by the SELCO Foundation, within 2 weeks of notification.

14.12 Warranty:

The Bidder shall warrant that every material/product to be supplied shall be in accordance with the specifications agreed upon by both parties. The items should be consistent with the established, recognized or stipulated standards for material of the type usually used for the purpose and in full conformity with the specifications and drawings or samples, if any, outlined by the SELCO Foundation in the tender documents and agreed upon by the Bidder by the virtue of acceptance of the WO by the bidder. Products offered must withstand normal operating conditions. The warranty shall continue notwithstanding inspection, payment, acceptance of tendered product and shall expire except in respect of complaints notified to Bidder prior to such date within 60 months from the date of commissioning. The warrant will be according to manufacturer's warranty policies.

14.13 Performance Guarantee:

The Bidder shall guarantee that any/all material used in execution of the Work Order shall be in strict compliance with characteristics requirements and specifications agreed upon. The Bidder shall guarantee that all material and products shall be repaired or replaced, as the case may be, at his own expense in case the same have been found to be defective in respect of material, workmanship for smooth and rated operation within a period of 60 months from the date of commissioning. Acceptance by the SELCO Foundation of any product and materials or their replacement will not relieve the Bidder of his/its responsibility concerning the above guarantee. In case of any legal case against the SELCO Foundation by any ultimate user of the product with respect to the performance of the system (during the warranty period), the SELCO Foundation shall not be held liable in such cases and the Bidder should support the SELCO Foundation with required and relevant technical testing and reports supporting the performance of the product and to defend that the non-performance of the product is not because of any manufacturing defect. The warranty replacements will be made within 15 to 20 working days from the date of receipt of the Complaint at the site.

14.14 Indemnity:

The Bidder shall at all times indemnify the SELCO Foundation against all claims which may be made in respect of stores for infringement of any right protected by patent, registration of design or trademark or other intellectual property, whether registered or not. Provided always that in the event of any claim in respect of alleged breach of patent, registered designs or trademark and other intellectual property whether registered or not, being made against the SELCO Foundation, the SELCO Foundation shall notify the Bidder of the same and the Bidder shall indemnify and hold the SELCO Foundation harmless at his own expense either settle any such dispute or conduct any litigation that may arise there from.

The Bidder shall, indemnify, defend and hold the SELCO Foundation and its officers, directors, representatives and assigns harmless from and against any liability or any other loss that may occur, arising from or relating to a breach of any of the terms or obligations under this Contract or any acts, errors, representations, fraudulent acts, misrepresentations, willful misconduct or negligence of the Bidder its employees, sub bidders and agents in performance of its obligations under this Contract.

14.15 Other Clauses:

- a. The Bidder will treat all information disclosed to it by the SELCO Foundation under this agreement as information with proprietary value and will not disclose the same to any outsiders or use any such information, either directly or indirectly, in whole or in part, for any commercial or non-commercial purposes. Bidder will not at any time, except under legal process, divulge any trade or business secret relating to the SELCO Foundation or any customer or agent of the SELCO Foundation, which may become known by virtue of the position as Bidder.
- b. All information that is developed during the Term in relation to the Project which shall include but not be limited to information collected through the remote monitoring system and other information, shall solely belong to the SELCO Foundation.
- c. Either party may terminate this contract forthwith in the event of any fraud or misconduct on part of the other party by providing a thirty-day written notice to such other Party. The SELCO Foundation may terminate this contract in the event of delay in supply/ installation of the products by the Bidder beyond 15 days from what is stipulated in the WO or the Bidder may terminate in the event of 3 consecutive delays of 15 days from what is agreed to between the parties in making payment to the Bidder in the absence of justifiable reasons intimated by writing. Any notice to be given hereunder shall be sufficiently given to the other party if forwarded by registered post or by Courier Service to the registered address of the other party mentioned in this agreement or the last known postal address of the other party or is send to the other Party's provided email. Upon the termination of this contract, the Bidder shall refund the entire amount paid by the SELCO Foundation. The Bidder shall deliver all deeds, documents and paper in his possession relating to the business of the SELCO Foundation and further certify the same in writing.
- d. Both the SELCO Foundation and the Bidder fully and freely intend to create an independent Bidder relationship under this Agreement. Nothing herein shall be deemed to establish a partnership, joint venture, association or employment relationship between the parties. Both parties agree that the Bidder has the right to control the manner and means employed in performing their activities under this Agreement. The Bidder shall update and inform the SELCO Foundation in writing of the various methods used to perform such activities in a timely manner. The SELCO Foundation shall further have the right to suggest and direct the Bidder to use other methods or refrain from using certain methods when performing such activities.

- e. The SELCO Foundation represents and warrants that (a) it has the full right and authority to enter into this Agreement, and no consent or authorization not obtained prior to the Effective Date is necessary to be obtained, (b) the SELCO Foundation is a charitable trust registered under the laws of India and is authorized to do business to the extent necessary to fulfil its obligations hereunder.
- f. Except as specifically set forth in this Agreement, neither party makes any representation or warranty of any kind, express or implied, including without limitation any warranty of merchantability, any warranty of fitness for a particular purpose or use, any warranty of non-infringement, or any other statutory warranty. Each party expressly disclaims any and all implied warranties.
- g. This agreement shall not be amended or renewed, except in writing mutually agreed by both parties. The project shall be fully completed as agreed in the above-mentioned terms and conditions.
- h. Notwithstanding anything else to the contrary: -
 - Bidder 's total aggregate liability under this Agreement shall not in any case exceed 100% of the value of this Agreement;
 - neither party shall be liable for any indirect, consequential, special, remote, exemplary, punitive or speculative losses or any losses or damages for loss of profits or business even if such party has been advised of the possibility of such costs or damages; and
 - The Bidder shall have no liability for matters outside of its own scope of works.
- i. In the event that any or any part of the provisions contained in this Agreement is determined to be invalid, unlawful or unenforceable to any extent, such provision shall be severed from the remaining provisions which shall continue to be valid and enforceable to the fullest extent permitted by law.
- j. The SELCO Foundation shall not either directly or indirectly assign, transfer, charge or in any manner make, offer or purport to assign, transfer or charge this Agreement or any rights herein or any part thereof without the previous consent in writing of the Bidder.
- k. Neither Parties shall during the term of this Agreement and for a period of one (1) year thereafter, either directly or indirectly, through any Third Party (ies) recruit, solicit, discuss employment with, hire, employ or induce any such individual to leave the employment of the other Party, unless prior written consent is obtained from the Party.
- l. Neither Party shall make any announcement relating to this Contract or any matter arising in respect of this or its relationship with the other Party, without the prior written consent of the other Party, which consent will not be unduly withheld.
- m. Parties shall not use any trademark, trade name, service mark, service name, copyright, logo or other intellectual property of the other Party without the prior written consent of such Party. For avoidance of doubt, Parties shall seek prior written consent each time when it intends to use trademark, trade name, service mark, service name, copyright, patent, or logo of the other Party.
- n. **Governing Law and Arbitration:** The Parties agree that this Agreement shall be governed and construed in accordance with the laws of India. The Parties hereto agree that they shall use all reasonable efforts to resolve between themselves any disputes, controversy or claim arising out of or relating to this Agreement. If the Parties fail to resolve the matter within the 60 days of occurrence of any dispute, such dispute, controversy or claim shall be settled by binding arbitration under the Indian Arbitration and Conciliation Act, 1996. There shall be one arbitrator mutually appointed by the Parties. The place of arbitration shall be Bangalore and the arbitration proceedings shall be in English. The courts at Bangalore alone shall have the jurisdiction to entertain and, or try any dispute arising out of or in connection with or in relation to the terms of this Agreement.

ANNEXURE 1: TECHNICAL SPECIFICATIONS OF SOLUTIONS

Bill of Materials for Solar System 1:- 1.1 Kwp

Sl. No	Products	Capacity	Qty	Unit
1	Solar Module (144 Cell)- 1Sx 2P	Solar Photovoltaic Array of Minimum Capacity 550 Wp (Monoperc) Panel Make and Model should be approved under MNRE ALMM List	2	No's
2	Solar Off-Grid inverter	1.4 kVA Single Phase – Wall mount	1	no
3	MMS	Solar PV Module support structure. MMS with the required inclination as per the location It should withstand the wind speed of 100 – 150 km/hr It should be suitable for above mentioned solar module - As per Sl.No. 1	1	set
4	AJB with SPD and MCB.	2 IN - 1 Out MCB Rating : 500 Vdc, 40 A (Double Pole) SPD Rating: 100 Vdc, Type 2, 40 KA (Double pole with indicators) Inline DC Fuse rating*: (+ve Strings): 20 A X 2 nos. Inter connection of the components inside the AJB should be DC cable of 10 Sq.mm	1	no
5	ACDB 230 V, with grid changeover	MCB Rating : 230 Vac, 16 A (Double Pole) SPD Rating : 320 Vac, Type 2, 40 kA (Double pole with indicators) Inter connection of the components inside the GIPB should be 4 Sq.mm	1	no
6	Cables red (M-M),DC cable	CU x PV1F , 1C x 6 sqmm	5	m
7	Cables black (M-M),DC cable	CU x PV1F , 1C x 6 sqmm	5	m
8	Cables red (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
9	Cables black (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
10	Cables (Inverter to ACDB to Load)	Cu x PVC, 2C x 4 sqmm	10	m
11	Solar Battery - VRLA (100 Ah,24 V)	Valve regulated lead-acid (VRLA) battery -C – 10, 100 Ah, 12 V	2	nos
12	Cables red (B-I) ,	CU x PVC, 1C x 16 sqmm	3	m
13	Cables black (B-I)	CU x PVC, 1C x 16 sqmm	3	m
14	Earthing kit for AC and DC	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)	2	sets
15	Earthing kit for lightning protection	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts	1	sets

		assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)		
16	Lightning Protection System- Passive type	Lightning arrester Solid Aluminium Alloy of 15 mm diameter and 2000 mm long with base plate should be used. GI Elevation pole 40 mm diameter, 3000 mm height. Supporting wires to be incorporated for stability to withstand wind speed of 100 – 150 km/hr. Ceramic insulation to be provided between lightning arrester base plate and GI elevation pole.	1	sets
17	LPS-Down Conductor	Insulated (outdoor) GI strip of size 25 x 3 mm to be used. Each joint should consist of 2 - hexagonal nut and bolt assembly. Saddle insulators to be provided along the length of the down conductor. Termination to the earthing electrode using SS Test links with clamps	20	m
18	Earthing Cable panel and structure	CU x PVC, 1C x 4 sq.mm	20	m
19	Earthing cable for inverter	CU x PVC, 1C x 4 sq.mm	20	m
20	Consumables	Includes: UPVC pipes and fittings, Flexible pipes, Screws, Nuts and Bolts etc	1	set
21	Civil work		1	no
22	Single Line Diagram - (SLD) for the system	Sun board with 3 mm Thickness - 4 ft x 2 ft	1	no
23	Do's and Don'ts Practices Poster (Solar Panels, Battery and CCU)	Foam Plaque - A4 Size for each	1	no
24	Signboard for Danger, No Fire and PASS	Danger - Electric shock - A4 No Fire - A5 PASS - A4	1	each
25	RMS	Cloud based remote monitoring system with dashboard along with WI FI router (GSM based network with all the brands)	1	no

For detailed technical specifications refer Annexure-2

Bill of Materials for Solar System 2 -: 2 kWp

Sl. No.	Products	Capacity	Qty	Unit
1	Solar Module (144 Cell)- 3Sx 1P	Solar Photovoltaic Array of Minimum Capacity 550 Wp (Monoperc) Panel Make and Model should be approved under MNRE ALMM List	3	Wp, nos
2	Solar Off-Grid inverter	2.5 kVA Single Phase – wall mount	1	no
3	MMS	Solar PV Module support structure. MMS with the required inclination as per the location It should withstand the wind speed of 100 – 150 km/hr It should be suitable for above mentioned solar module - As per Sl.No. 1	1	set
4	AJB with SPD and MCB.	1 IN - 1 Out, MCB Rating: 500 Vdc, 20 A (Double Pole) SPD Rating: 250 Vdc, Type 2, 40 KA (Double pole with indicators) Inline DC Fuse rating*: (+ve Strings): 20 A X 1 nos. Inter connection of the components inside the AJB should be DC cable of 6 Sq.mm	1	no
5	ACDB 230 V , with grid changeover	MCB Rating : 230 Vac, 16 A (Double Pole) SPD Rating : 320 Vac, Type 2, 40 kA (Double pole with indicators) Inter connection of the components inside the GIPB should be 4 Sq.mm	1	no
6	Cables red (M-M),DC cable	CU x PV1F, 1C x 6 sqmm	5	m
7	Cables black (M-M),DC cable	CU x PV1F, 1C x 6 sqmm	5	m
8	Cables red (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
9	Cables black (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
10	Cables (Inverter to ACDB to Load)	Cu x PVC, 2C x 4 sqmm	10	m
11	Solar Battery - VRLA (200 Ah,48V)	Valve regulated lead-acid (VRLA) battery -C – 10, 200 Ah, 12 V	4	nos
12	Cables red (B-I) ,	CU x PVC, 1C x 25 sqmm	3	m
13	Cables black (B-I)	CU x PVC, 1C x 25 sqmm	3	m
14	Earthing kit for AC and DC	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)	2	sets
15	Earthing kit for lightning protection	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made.	1	sets

		Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)		
16	Lightning Protection System- Passive type	Lightning arrester Solid Aluminium Alloy of 15 mm diameter and 2000 mm long with base plate should be used. GI Elevation pole 40 mm diameter, 3000 mm height. Supporting wires to be incorporated for stability to withstand wind speed of 100 – 150 km/hr. Ceramic insulation to be provided between lightning arrester base plate and GI elevation pole.	1	sets
17	Cable/Down conductor for Lightning Arrester	Insulated (outdoor) GI strip of size 25 x 3 mm to be used. Each joint should consist of 2 - hexagonal nut and bolt assembly. Saddle insulators to be provided along the length of the down conductor. Termination to the earthing electrode using SS Test links with clamps	20	m
18	Earthing Cable panel and structure	CU x PVC, 1C x 4 sq.mm	20	m
19	Earthing cable for inverter	CU x PVC, 1C x 4 sq.mm	20	m
20	Consumables	Includes: UPVC pipes and fittings, Flexible pipes, Screws, Nuts and Bolts etc	1	set
21	Civil work		1	no
22	Single Line Diagram - (SLD) for the system	Sun board with 3 mm Thickness - 4 ft x 2 ft	1	no
23	Do's and Don'ts Practices Poster (Solar Panels, Battery and CCU)	Foam Plaque - A4 Size for each	1	no
24	Signboard for Danger, No Fire and PASS	Danger - Electric shock - A4 No Fire - A5 PASS - A4	1	each
25	RMS		1	no

For detailed technical specifications refer Annexure-2

Bill of Materials for Solar System 3 -: 3 kWp

Sl.No.	Products	Capacity	Quantity	Unit
1	Solar Module (144 Cell)- 2Sx 2P	Solar Photovoltaic Array of Minimum Capacity 550 Wp (Monoperc) Panel Make and Model should be approved under MNRE ALMM List	4	Wp, nos
2	Solar offgrid inverter	4 kVA Single Phase – wall mount	1	no
3	MMS	Solar PV Module support structure. MMS with the required inclination as per the location It should withstand the wind speed of 100 – 150 km/hr It should be suitable for above mentioned solar module - As per Sl.No. 1	1	set
4	AJB with SPD and MCB.	2 IN - 1 OUT, MCB Rating: 500 Vdc, 40A (Double Pole) SPD Rating: 180 Vdc, Type 2, 40 KA (Double pole with indicators) Inline DC Fuse rating*: (+ve Strings): 20 A X 2 nos. Inter connection of the components inside the AJB should be DC cable of 6 Sq.mm	1	no
5	ACDB 230 V , with grid changeover	MCB Rating : 230 Vac, 32 A (Double Pole) SPD Rating : 320 Vac, Type 2, 40 kA (Double pole with indicators) Inter connection of the components inside the GIPB should be 4 Sq.mm	1	no
6	Cables red (M-M),DC cable	CU x PV1F, 1C x 6 sqmm	6	m
7	Cables black (M-M),DC cable	CU x PV1F , 1C x 6 sqmm	6	m
8	Cables red (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
9	Cables black (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
10	Cables (Inverter to ACDB to Load)	Cu x PVC, 2C x 4 sqmm	10	m
11	Solar Battery - VRLA (200 Ah,48V)	Valve regulated lead-acid (VRLA) battery -C – 10, 200 Ah, 12 V	4	nos
12	Cables red (B-I)	CU x PVC, 1C x 25 sqmm	3	m
13	Cables black (B-I)	CU x PVC, 1C x 25 sqmm	3	m
14	Earthing kit for AC and DC	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)	2	sets
15	Earthing kit for lightening protection	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with	1	sets

		Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)		
16	Lightning Protection System-Passive type	Lightning arrester Solid Aluminium Alloy of 15 mm diameter and 2000 mm long with base plate should be used. GI Elevation pole 40 mm diameter, 3000 mm height. Supporting wires to be incorporated for stability to withstand wind speed of 100 – 150 km/hr. Ceramic insulation to be provided between lightning arrester base plate and GI elevation pole.	1	sets
17	Cable/Down conductor for Lightning Arrester	Insulated (outdoor) GI strip of size 25 x 3 mm to be used. Each joint should consist of 2 - hexagonal nut and bolt assembly. Saddle insulators to be provided along the length of the down conductor. Termination to the earthing electrode using SS Test links with clamps	20	m
18	Earthing Cable panel and structure	CU x PVC, 1C x 4 sq.mm	20	m
19	Earthing cable for inverter	CU x PVC, 1C x 4 sq.mm	20	m
20	Consumables	Includes: UPVC pipes and fittings, Flexible pipes, Screws, Nuts and Bolts etc	1	set
21	Civil work		1	no
22	Single Line Diagram - (SLD) for the system	Sun board with 3 mm Thickness - 4 ft x 2 ft	1	no
23	Do's and Don'ts Practices Poster (Solar Panels, Battery and CCU)	Foam Plaque - A4 Size for each	1	no
24	Signboard for Danger, No Fire and PASS	Danger - Electric shock - A4 No Fire - A5 PASS - A4	1	each
25	RMS	Cloud based remote monitoring system with dashboard along with WI FI router (GSM based network with all the brands)	1	no

For detailed technical specifications refer Annexure-2

Bill of Materials for Solar System 4: 5Kwp -Single Phase

Sl.No.	Products	Capacity	Quantity	Unit
1	Solar Module (144 Cell)- 9Sx 1P	Solar Photovoltaic Array of Minimum Capacity 550 Wp (Monoperc) Panel Make and Model should be approved under MNRE ALMM List	9	Wp, nos
2	Solar offgrid inverter	6 kVA Single Phase – wall mount	1	no
3	MMS	Solar PV Module support structure. MMS with the required inclination as per the location It should withstand the wind speed of 100 – 150 km/hr It should be suitable for above mentioned solar module - As per Sl.No. 1	1	set
4	AJB with SPD and MCB.	1 IN - 1 OUT, MCB Rating: 800 Vdc, 20A (Double Pole) SPD Rating: 600 Vdc, Type 2, 40 KA (Double pole with indicators) Inline DC Fuse rating*: (+ve Strings): 20 A X 1 nos. Inter connection of the components inside the AJB should be DC cable of 6 Sq.mm	1	no
5	ACDB 230 V , with grid changeover	MCB Rating : 230 Vac, 32 A (Double Pole) SPD Rating : 320 Vac, Type 2, 40 kA (Double pole with indicators) Inter connection of the components inside the GIPB should be 6 Sq.mm	1	no
6	Cables red (M-M),DC cable	CU x PV1F , 1C x 6 sqmm	8	m
7	Cables black (M-M),DC cable	CU x PV1F, 1C x 6 sqmm	8	m
8	Cables red (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
9	Cables black (AJB-I), DC cable	CU x PVC, 1C x 6 sqmm	20	m
10	Cables (Inverter to ACDB to Load)	Cu x PVC, 2C x 6 sqmm	10	m
11	Solar Battery - VRLA (200 Ah,96 V)	Valve regulated lead-acid (VRLA) battery -C – 10,200 Ah, 12 V	8	nos
12	Cables red (B-I)	CU x PVC, 1C x 16 sqmm	3	m
13	Cables black (B-I)	CU x PVC, 1C x 16 sqmm	3	m
14	Earthing kit for AC and DC	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)	2	sets
15	Earthing kit for lightning protection	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tin-coated copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should	1	sets

		be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)		
16	Lightning Protection System- Passive type	Lightning arrester Solid Aluminium Alloy of 15 mm diameter and 2000 mm long with base plate should be used. GI Elevation pole 40 mm diameter, 3000 mm height. Supporting wires to be incorporated for stability to withstand wind speed of 100 – 150 km/hr. Ceramic insulation to be provided between lightning arrester base plate and GI elevation pole.	1	sets
17	Cable/Down conductor for LightningArrester	Insulated (outdoor) GI strip of size 25 x 3 mm to be used. Each joint should consist of 2 - hexagonal nut and bolt assembly. Saddle insulators to be provided along the length of the down conductor. Termination to the earthing electrode using SS Test links with clamps	20	m
18	Earthing Cable panel and structure	CU x PVC, 1C x 4 sq.mm	20	m
19	Earthing cable for inverter	CU x PVC, 1C x 4 sq.mm	20	m
20	Consumables	Includes: UPVC pipes and fittings, Flexible pipes, Screws, Nuts and Bolts etc	1	set
21	Civil work		1	no
22	Single Line Diagram - (SLD) for the system	Sun board with 3 mm Thickness - 4 ft x 2 ft	1	no
23	Do's and Don'ts Practices Poster (Solar Panels, Battery and CCU)	Foam Plaque - A4 Size for each	1	no
24	Signboard for Danger, No Fire and PASS	Danger - Electric shock - A4 No Fire - A5 PASS - A4	1	each
25	RMS	Cloud based remote monitoring system with dashboard along with WI FI router (GSM based network with all the brands)	1	no

For detailed technical specifications refer Annexure-2

Bill of Materials for Solar System 4: 5Kwp -Three Phase

Sl.No	Products	Capacity	Quantity	Unit
1	Solar Module (144 Cells)- 5Sx 2P	Solar Photovoltaic Array of Minimum Capacity 550 Wp (Monoperc) Panel Make and Model should be approved under MNRE ALMM List	10	Wp, nos
2	MMS,RCC	Solar PV Module support structure. MMS with the required inclination as per the location It should withstand the wind speed of 100 – 150 km/hr It should be suitable for above mentioned solar module - As per Sl.No. 1	1	set
3	Solar off grid inverter	7.5 KVA, Three Phase – wall mount	1	Nos
4	Solar Battery, VRLA type(200 AH, 96V system)	Valve regulated lead-acid (VRLA) battery -C – 10,200 AH	8	Nos
5	AJB with SPD and MCB.	2 IN 1 OUT MCB Rating : 500 Vdc, 40 A (Double Pole) SPD Rating: 300 Vdc, Type 2, 40 KA (Double pole with indicators) Inline DC Fuse rating*: (+ve Strings): 20 A X 2 nos. Inter connection of the components inside the AJB should be DC cable of 10 Sq.mm	1	Nos
6	ACDB 415 V with grid changeover	MCB Rating : 415 Vac, 16 A (Four Pole) SPD Rating : 320 Vac, Type 2, 40 kA (Four pole with indicators) Inter connection of the components inside the GIPB should be 6 Sq.mm	1	Nos
7	Cable's red (M-M),DC cable	CU x PV1F , 1C x 6 sq. mm.	10	m
8	Cable's black (M-M),DC cable	CU x PV1F, 1C x 6 sq. mm.	10	m
9	Cable's red (AJB-I), DC cable	CU x PVC, 1C x 6 Sq.mm	20	m
10	Cable's black (AJB-I), DC cable	CU x PVC, 1C x 6 Sq.mm	20	m
11	Inverter to ACDB ,ACDB to load	CU x PVC, 4C x 6 Sq.mm	10	m
12	Cable (B-I),Red	CU x PVC, 1C x 25 sqmm	3	m
13	Cable (B-I)Black	CU x PVC, 1C x 25 Sq.mm	3	m
14	Earthing Cable for panel and structure	CU x PVC, 1C x 4 sq.mm	30	m
15	Earthing cable for inverter	CU x PVC, 1C x 6 sq.mm	20	m
16	Earthing kit for AC and DC	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tinned copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)	2	set
17	Earthing kit for lightning protection	Solid electrode (Steel) Bonded copper – 16 mm diameter, 2000 mm long with 250 microns Bonding thickness, tinned copper lugs with insulation, clamps with nut-bolts assembly. protective concrete construction (Chamber) to	1	set

		earthing pit (L x B x H - 1.5 x 1.5 x 1.5 feet) with Metallic/FRP lid should be made. Earthing pit size should be minimum of 6 inch diameter and should be filled with back fill compound. Typology – Equipotential (Refer Annexure 2)		
18	Lightning Protection System, Passive type	Lightning arrester Solid Aluminium Alloy of 15 mm diameter and 2000 mm long with base plate should be used. GI Elevation pole 40 mm diameter, 3000 mm height. Supporting wires to be incorporated for stability to withstand wind speed of 100 – 150 km/hr. Ceramic insulation to be provided between lightning arrester base plate and GI elevation pole.	1	set
19	Cable/Down conductor for Lightning Arrester	Insulated (outdoor) GI strip of size 25 x 3 mm to be used. Each joint should consist of 2 - hexagonal nut and bolt assembly. Saddle insulators to be provided along the length of the down conductor. Termination to the earthing electrode using SS Test links with clamps	20	m
20	Consumables	Includes: UPVC pipes and fittings, Flexible pipes, Screws, Nuts and Bolts etc	1	Set
21	Civil work		1	-
22	Single Line Diagram - (SLD) for the system	Sun board with 3 mm Thickness - 4 ft x 2 ft	1	no
23	Do's and Don'ts Practices Poster (Solar Panels, Battery and CCU)	Foam Plaque - A4 Size for each	1	no
24	Signboard for Danger, No Fire and PASS	Danger - Electric shock - A4 No Fire - A5 PASS - A4	1	each
25	RMS	Cloud based remote monitoring system with dashboard along with WI FI router (GSM based network with all the brands)	1	no

For detailed technical specifications refer Annexure-2

ANNEXURE 2- TECHNICAL SPECIFICATIONS OF COMPONENTS

The proposed project shall be commissioned as per the technical specifications given below. Any shortcomings or deviations may lead to the cancellation of the Letter of Award, and in such a case the Competent Authority's decision will be final and binding on the bidder.

1. SOLAR PV MODULE:

- a. The PV modules used must qualify to the latest edition of the IEC PV module qualification test.
- b. The total solar PV array capacity should not be less than the allocated capacity and should comprise solar crystalline modules of minimum Wp mentioned in the bill of materials. Module capacity less than minimum Wp mentioned in the BoM / Purchase Order shall not be accepted.
- c. PV modules must be tested and approved by one of the IEC authorized test centers. The module frame shall be made of corrosion-resistant materials, preferably anodized aluminum of 10 microns thickness.

NOTE:

- Approval from SELCO Foundation should be sought before finalizing the choice of brand for SPV modules.

2. MODULE WARRANTY:

Module Warranty is defined as: The manufacturer should warrant the Solar Module(s) to be free from the defects and/or failures specified below for a period not less than Ten (10) years from the date of sale to the original customer

- a. Defects and/or failures due to manufacturing.
- b. Defects and/or failures due to quality of materials
- c. Non-conformity to specifications due to faulty manufacturing and/or inspection processes. If the solar Module(s) fails to conform to this warranty, the manufacturer will repair or replace the solar module(s), at the supplier's sole cost

3. PERFORMANCE WARRANTY:

- The degradation of power generated by the module shall not exceed 20% of the maximum rated power over the 25-year period and not more than 8% after the first ten years period.
- Should have a positive power tolerance
- Should be Anti - L.eT.I.D & P.I.D Resistant
- Panel degradation should be linear over a period for 25+ years
- Should have temperature coefficient of power (P_{max}) $\leq -0.38\% / ^\circ\text{C}$
- Should be able to withstand downward force ≥ 5600 pascals
- Should be able to withstand uplift force ≥ 2400 pascals
- Should have tempered/toughened solar glass of 3.2 mm thickness
- Should have anti-reflective surface treatment
- Should have optically clear glass with high transmittance

Additionally, modules should be certified with:

- PV module safety standards
- PID-d.
- Ammonia corrosion Resistance test
- Dynamic Mechanical Load

- Hailstone (35mm)
- Ignitability test
- FSI Tested.
- EL Tested.
- Enlisted Module Manufacturer of DGS&D.
- Application class - Class A (Electric hazard test - Operating voltage >50 Vdc & Modules area can be accessed by public)
- Module fire performance - Type 1 (Burning test & spread of flame test)

4. MODULE MOUNTING STRUCTURE (MMS):

For very low elevation & flat RCC surface mounting:

- Landscape orientation to be incorporated.
- Triangular MMS to be chosen.
- The MMS should be mounted to the RCC roof using wedge anchor fasteners and a concrete block of L x W x H = 1.5 x 1.5 x 0.25 feet at the front side of the MMS and concrete block of L x W x H = 1.5 x 1.5 x 0.75 feet at the back side of the MMS respectively. The sides of the cube and roof interface should be given a simple 1-inch filet construction. At the top side of the cubes, an upward taper should be formed from cube sides towards M.M.S leg. M15/M20 grade P.C.C should be used for the civil works with minimum 3 days of curing.

For inclined sheet roofs/Tin roofs (General purpose mounting):

- Mini rails to be incorporated
- Anodised mini rails of 70 microns thickness.
- Rail dimension should be of 300 mm X 40 mm with minimum thickness of 2.6 mm
- Distance between Solar panel to rail should be minimum 100 mm.
- Mini rails can be fastened to the purlins using self-driven screws. (Pop riveting can be incorporated on PPGL sheets which are in good condition.)
- EPDM strips to be used as sealant for waterproofing.

For roofs which are unfit for mounting panels:

- Roofs that are not fit for installation due to less structural stability/very old roofs/rainwater leakage problem, then a suitable location on the ground may be preferred for the panel installation.
- The installation maybe a low elevation MMS with fencing protection around or may be a high elevation MMS (Approval and support from SELCO foundation should be taken prior to installation)

Orientation of the MMS:

- The orientation of the MMS should be due south in general case/flat mounting surfaces.
- If the roof orientation of the building is deviated away from the south (by less than 30 degrees), then the existing orientation of the building roof can be used for mounting the panels. If the deviation is more than 30 degrees, then action to correct the deviation should be taken only after consultation with SELCO Foundation.

NOTE:

- Approval from SELCO Foundation should be sought before finalizing the MMS design in case

of any customization required as per the existing site situations.

- Approval from SELCO Foundation should be sought to mount the panels on an alternate location if the existing roof is unfit for mounting panels.

General guidelines:

- Each structure should have an angle of inclination as per the geographical location to receive maximum irradiation.
- All panels should be grounded together with grounding lugs and all the MMS structure should be grounded using grounding clips and should be connected to the respective earthing pit along with AJB.
- All nuts & bolts used should be made of G.I (> 120 microns) or of stainless steel.
- The structure shall be designed to allow easy replacement of any module with walking space around the MMS. The array structure shall be so designed that it will occupy minimum space without sacrificing the output from the SPV panels. Installation of solar structures should not damage the roof in any way. If any concrete or foundation is required, it should be precast type.
- Bidders must follow the above types of roof mounting options, and the solution is dependent on the type of roof at the location. a) Flat roof, b) Tin roof. In all cases, considerations must be made for the roof's age, structural integrity, access to equipment, and necessary setbacks for fire and life safety requirements.

5. ARRAY JUNCTION BOX/COMBINER BOXES:

- The junction box should have good resistances against mechanical stresses and external impacts.
- The junction boxes are to be provided in the PV array for termination of connecting cables.
- The Junction Boxes (JBs) shall be made of GRP/FRP/Powder Coated Aluminium /cast aluminium alloy with full dust, water & vermin proof arrangement.
- All wires/cables must be terminated through cable lugs. The boxes shall be such that input & output termination can be made through suitable cable glands.
- Proper cable lugs (Fork, pin type) with insulation should be provided for the cables connected with the boxes.
- A.J.B should have segregated inputs for both positive and negative cables emerging from the respective arrays.
- Positive strings should have a self-blown in-line DC fuses
- All the glands provided under the junction box should be used and any unused glands should be sealed for ingress protection.
- Suitable markings shall be provided on the busbar for easy identification and the cable ferrules must be fitted at the cable termination points for identification.
- The AJB should be placed in a shaded place, preferably at the inner side of the wall nearest to the roof.
- IP rating: IP-67.
- Should comply with the R.o.H.S. Directive 2002/95/EC

6. Battery:

The battery chosen for the project should have the following characteristics:

- **Battery type:** Valve Regulated Lead Acid (VRLA)
- **Plate technology:** Flat plate
- **Terminal type:** L - Type
- **Operating temperature:** -20°C to +55°C
- **Application** - Cyclic application, Float application above 1 hour discharge rate
- **Self-discharge @ STC** - Low self-discharge < 3.0 % per month
- **Life cycle @ 80% D.O.D @ 27°C** - 1500 cycles
- **Ah Efficiency:** >90 %
- **Wh Efficiency:** >80 %

Should have **additional characteristics of:**

- Should exhibit PSOC behavior
- Should have low fumes generation
- Should perform easy recovery after idle period.
- All the batteries capacities mentioned are at a C/10 rate of discharge and the same should also be followed by the bidder. The preferred voltage of each battery is 12 V due to better space utilization. However, bidders quoting for battery banks with 2V cells or other capacities should add a justification note as annexure to why the particular voltage was opted for. The technical committee will consider this and take a decision on the suitability of such an option. The decision of the technical committee/technical member of the buyer on this matter will be final and binding on the bidder.
- Battery should confirm to the latest B.I.S/ International standards. A copy of the relevant test certificate for the battery should be furnished.
- The battery should be warranted for a minimum of 5 years.
- The battery should be installed inside the premises of the end user on a battery rack. The rack material size should be able to easily bear the battery load. (Each leg should have a respective base plate.)
- The rack's row length should be considered based on the size of the battery as well as the number of batteries placed per row including the 2-inch inter battery gap.
- Support rails of 6-inch height should be provided at the shorter side of the racks to support batteries from fall due to accidental impacts.
- In case of double row racks, the inter row height should be of a minimum 18-inch separation.
- The battery rack should be of fireproof material and corrosion free (GI rack is preferable).
- In the battery rack, each joints should be with nut and bolt assembly and should not be with any type of welding assembly.
- Electrical Insulation mats (IS 15652:2006 standard) with minimum 0.4 kV insulation capacity should be provided on the floor.
- Tin-coated copper lugs (Ring type) with insulation to be used at cable ends to connect each battery terminal.
- Spring washers to be incorporated in the nut-bolt assembly at each battery terminal.
- Battery terminal caps used, should be big enough to cover the entire terminal area and the nut bolt assembly.
- At each battery terminal, petroleum-based gel coating should be applied.
- All cables connecting to the batteries should be provided "conduit pipe" protection and tied to the outer sides of the battery body using cable ties.

NOTE:

Placement of battery should be in proper ventilated room and if not then ventilation in the room should be compulsorily incorporated for the following reasons:

- Safety of the system
- Safety of the end users
- Efficient performance of the system.

Also, approval from SELCO Foundation should be sought before finalizing the choice of brand for solar batteries.

7. ACDB with inbuilt Changeover:

The ACDB box should have good resistances against mechanical stresses and external impacts. The Box shall be made of GRP/FRP/Powder Coated Aluminium /cast aluminium alloy with full dust, water & vermin proof arrangement.

- All wires/cables must be terminated through cable lugs.
- The boxes shall be such that input & output termination can be made through suitable cable glands.
- All the cables (Incoming & Outgoing) should be kept separated and should be given UPVC conduit pipe protection
- All the glands provided under the box should be used and any unused glands should be sealed for ingress protection.
- Preferably, the box should be placed in the PCU room.
- IP rating: IP-67.
- Proper cable lugs (Pin type) with insulation should be provided for the cables connected with the boxes.
- Should comply with the R.o.H.S. Directive 2002/95/EC

8. Solar OFF-GRID PCU:

The power conditioning unit should be provided to convert DC power produced by SPV modules into AC power. The power conditioning unit/inverter should be off-Grid with Grid interactive and grid charging features.

Typical technical features of the PCU shall be as follows:

Power conditioning unit with inbuilt charge controller of capacity & ratings as specified in the below for various capacities of Solar Power Plants should convert DC power into AC power.

The PCU should be tested from the MNRE approved test centres / NABL /BIS accredited testing-calibration laboratories. In the case of imported power conditioning units, these should be approved by international test houses.

In case of inverters with low ground clearance, a minimum of 3-inch elevation for the same should be incorporated. The elevating means should be a fireproof material (Leg bushes are preferable).

8.1.1 The PCU will have the following features:

- a. MPPT charging.
- b. Inverter efficiency should be more than 85%
- c. The inverter should be compatible with alternators / Generators.
- d. Output voltage for single phase 230 V, +/-3% with pure sine wave.
- e. Output voltage for Three phase 415 V +/-3% with pure sine wave.
- f. Output frequency: 50 Hz
- g. Capacity of PCU is specified at minimum 0.8 lagging power factor
- h. THD: less than 3%
- i. Ambient temperature 50 degree Celsius (max.)
- j. Operating humidity 95% maximum
- k. Shall be equipped with RS 485 data port output

8.1.2 Protections:

- a. Over voltage (automatic shutdown)
- b. Under voltage (automatic shutdown)
- c. Overload - Short circuit (circuit breaker & electronics protection against sustained fault)
- d. Over Temperature
- e. Temperature compensation
- f. Battery, PV reverse polarity

8.1.3 Indicators

- a. Array on
- b. MPPT charger on
- c. Battery connected, charging
- d. Inverter ON
- e. Load on solar/ battery
- f. Grid charger on
- g. Load on Grid
- h. Grid on
- i. Fault

8.1.4 Display Parameters

- a. Battery Current
- b. Battery Voltage
- c. PV Panels Voltage
- d. PV Panels Current
- e. Energy Generation (kWh)
- f. Energy – Grid Export (kWh)
- g. Grid Voltage
- h. PCU Load (kW)
- i. PCU Output Voltage
- j. PCU Output Frequency
- k. PCU Output Current
- l. Fault Codes

8.1.5 Cooling: cooling mechanism required - Air Cooled

NOTE:

Placement of PCU should be in proper ventilated room and if not then ventilation in the room should be compulsorily incorporated for the following reasons:

- Safety of the system
- Safety of the end users
- Efficient performance of the system.

Also, approval from SELCO Foundation should be sought before finalizing the choice of brand for solar PCU.

9. Protections:

The system should be provided with all necessary protections like earthing and lightning protection:-

1. LIGHTNING PROTECTION:

Code of practice for protective measures against lightning strikes and surges as per IS 2309-1989 and subsequent amendments should be followed. The main aim in this protection shall be to reduce the over voltage to a tolerable value before it reaches the PV or other sub system components. The source of over voltage can be lightning, atmosphere disturbances etc. The entire space occupying the SPV array shall be suitably protected against lightning by deploying the required number of lightning arresters.

To increase the coverage area of protection, the lightning arrestor should be given an additional elevation by using G.I. pole. The height of the lightning arrestor tip should be minimum 5 meters above the mounting surface. Insulation should be provided between the lightning arrestor and the elevation pole and the building structure. Down conductors should maintain 1.75 m distance from panels, arrays and other power cables around.

- Franklin Rods/Passive type lightning arresters should be incorporated.
- The entire lightning arrester set up (Air terminal pole, spikes and base plates should be of **(solid Aluminium Alloy)**).
- Minimum size of the lightning arrester should be 15 mm by diameter and 2000 mm by length.
- The base plate should be 90 mm X 90 mm X 5 mm in dimension
- GI Elevation pole 40 mm diameter and 3000 mm height.
- The lightning protection system incorporated in the installation is only for the protection of the solar PV systems installed.
- The lightning arrestor setup should always be vertical and should be stable against high wind loads.
- In case of RCC flat roofs, the lightning arrestor setup should be provided with anchor fasteners along with civil work made at its base plate.
- In case of metal sheet roof, the lightning arrestor should be placed at the apex of the roof . **T base clamps** should be made use of it to install the lightning arrestor.
- Supporting wires should be used for additional stability of the lightning arrestor.
- A concrete cube (Civil work) of 1.5 ft x 1.5 ft x 1.5 ft (L x B x H) dimensions should be set.

- The base of the clamp should be given EPDM strips which are to be used as sealant for waterproofing.
- The lightning arrester should be placed preferably at the back of the array and at the sides, with a separation distance of 1.75 meters only (From the panel edges).
- Down conductor for lightning arrester should be of insulated GI strip of size 25x3 mm should be used.
- Each joint should be connected with 2-hexagonal nut-bolt assembly (SS), no twisting or brazing.
- Down conductor to be connected to earthing rod with steel clamps and testlinks.

NOTE:

Copper bonded and G.I rods are not allowed in the installation.

Approval from SELCO Foundation should be sought before finalizing the choice of brand for lightning arresters.

2. EARTHING:

Code of practice for protective earthing and protection against electric shocks as per the IEC 62305 and latest standards should be followed. Earthing is a way of transmitting any instant electricity discharge directly to the ground by providing a low resistance path (using electrical cables wires with no joints or metal strips with lesser joints). This instant electricity discharge is mostly in the form of lightning, surge voltages entering through grid lines and due to fault current/leakage current in the system. The goal is to protect the appliances from voltage surges and protect the users from the risk of electrocution due to leakage/fault current in the system.

- Earthing type - Chemical Earthing
- Electrodes used should be a **Solid (Steel) copper-bonded electrode with 250 microns of bonding thickness**
- The electrode should be minimum of 16 mm by diameter and 2000 mm by length, placing should be 500 mm from ground level.
- Earth backfill compound - Clay based (High Moisture), Graphite based (For normal soil conditions) and Bentonite based (For rocky soil conditions) should be used.
- Earth pit should be filled with back fill compound.
- Earth pit should be 6-inch by diameter and 2500 mm by depth (As long as the electrode's length.)
- Individual earthing for AC Loads should be provided for these components: Grid input protection box, Inverter/PCU, Changeover Switches and connected loads. These all should be connected using MET (Main Earthing Terminal – Busbar).
- Individual earthing for DC Loads should be provided for these components: A.J.B and Battery rack. These all should be connected using MET (Main Earthing Terminal – Busbar).
- Individual earthing for Lightning Arrester should be provided.
- Interconnection of LA earthing - Each lightning arrester will have its respective down conductors going down to the respective earth pits. The lightning arresters are to be Inter-connected at the roof, to enhance the efficacy of the protection, using the down conductor same as the specified in the BOM. Additionally, the earthing pits allocated for the lightning arresters are to be interconnected below the ground (0.5 metres) to enhance the efficacy of the protection, using the down conductor same as the specified in the BOM. This equipotential

bonding approach needs to be strictly incorporated at all sites of installations.

- A minimum of 3 m distance between each pit must be maintained and 1.5 m from building foundations and sumps.
- Lightning arrester earthing pit should not be mixed with other earth pits and should be well spaced away from them.
- Earthing pits should have a chamber set at the ground level and should be closed with a metallic lid/F.R.P lid and should have access for maintenance.
- Cable lugs of 16 Sq.mm with insulation should be used for cable-type down conductors to connect with the electrode.
- Proper cable-to-rod & strip-to-rod clamps should be used.
- Clamp materials should be that of stainless steel.
- Earth pit resistance should ideally be 0.5 Ohms and should not exceed 5 Ohms.
- All the earth pits should be given an identification/markings to the devices/structures they are connected to.
- The earthing electrodes used in the project should have CPRI test certification.

NOTE:

G.I electrodes are not allowed in the installation.

Approval from SELCO Foundation should be sought before finalizing the choice of brand for earth electrodes.

10. CABLES (Over-ground cables):

GENERAL INDOOR/AC CABLES:

(Grid input to G.I.P.B -> Inverter -> Changeover switch -> Load distribution box) -> Changeover switch (Solar & Grid-DG input)

Stranded cable conductors should be made of high purity annealed 99.97% electrolytic grade copper with unadulterated FR PVC insulation.

Cable size as mentioned in the bill of materials to be used in the project.

The cables used shall have the following characteristics:

- High thermal stability and temperature withstanding range: -15°C to +85°C.
- Should have a temperature index of 300°C.
- Should have excellent resistance to heat, cold, water, oil, abrasion & UV radiation.
- Should have flexibility & higher bending capacity- 8D minimum bending radius (EFFR wires).
- Should have anti-rodent & anti-Termite resistant properties.
- Should have a high oxygen index (LOI) of > 30%.
- Should have high insulation resistance/Rated for nominal voltage (U_o/U): 600/1100 V.
- Should have low conductor resistance (Maximum conductor resistance at 20°C < 7.41 Ω).
- Should have low smoke density and emissivity (Corrosive halogen acid & toxic gasses below 18%).
- Should be 100% bunching & 100% conductive.
- Should be lead free.

NOTE:

The cables chosen for the project:

- should have passed the flame-resistant flammability test.
- Should confirm the sizing standards tests.
- Should be RoHS & Reach Compliant and should be NABL accredited.
- Cables of multiple brands should not be used in the installation.
- Should have the IEC, CE & ISI certification
- Cables of multiple brands should not be used in the installation

Also, approval from SELCO Foundation should be sought before finalizing the choice of brand for AC cables.

SOLAR CABLES/D.C. CABLES/OUTDOOR CABLES:

(Panels -> arrays -> A.J.B -> inverter)

Solar cables should have these specified constructional features:

Type PV1 - F (With double insulation)

- **Conductor:** Fine stranded Wire Tinned Copper Conductor according to BS EN 60228:2005 cl. 5
- **Insulation:** UV resistant, cross linkable, halogen free, flame-retardant compound for core insulation
- **Core Identification:** Red/Black
- **Sheath:** UV resistant, cross linkable, halogen free, flame-retardant compound for Sheath over insulation
- **Cable Colour:** Red/Black
- **Voltage Rating:** 0.6 / 1.0 kV

BATTERY CABLES:

(Battery -> Battery -> Inverter)

Battery cables should have these specified constructional features:

- **Cable type:** Flexible cable
- **Insulation type:** Double Insulation
- **Insulation material:** Rubber with Flame-retardant, Oil-resistant
- **Conductor:** Fine multi stranded wires, Tinned Copper Conductor
- **Cable colour:** Black
- **Core Identification:** White
- **Crimping:** Both ends crimped
- **Voltage Rating:** 0.6 / 1.0 kV

NOTE:

- Cables of multiple brands should not be used in the installation.
- Should have the IEC, CE & ISI certification

The DC cables chosen for the project should have the following tests passed:

- Flame resistant flammability test.

- The sizing standards tests
- RoHS & Reach compliant

Also, approval from SELCO Foundation should be sought before finalizing the choice of brand for DC cables.

A. - COLOR CODING & LABELING:

- Correct color codes should be followed for the laying of the cables.
- **For the DC side** - Red color for the positive side and Black color for the negative side should be incorporated and cables of other colors should not be used.
- **For the AC side/Single phase** - Both input and output (DB) of the inverter, Black color to be used for the neutral and Red color to be used for the line.
- **For the AC side/Three phase** - Both input and output (DB) of the inverter, Black color to be used for the neutral and Red, Blue & yellow color to be used for the lines.
- **For earthing** - Green-Yellow color should be used for the earth down conductors.
- **Labelling:**
- Each set of cables should be appropriately labelled by mentioning their origin point and their terminal point and should be easily identifiable for maintenance purposes.
- The components to which the cables are interconnected to, should be clearly labelled
- Labels should be made using permanent markers on white label tags

The cable should be so selected that it should be compatible up to the life of the solar PV panels i.e., twenty-five (25) operational years. Cable ends should be crimped along with cable lugs thoroughly using appropriate lugs. This cable-lug interface must be Insulated. Tin-coated copper cable lugs with respect to cable sizes should be used and they should be of required current ratings. Connectors (MC4) used for the solar cables should be of an IP-67 rating or higher.

Conduit pipe protection to be given to cables connecting:

1. Battery to battery,
2. Battery to inverter,
3. All cables entering the inverter.

DC/Solar cables from PV arrays and earthing cables should be given UPVC pipe protection. The end points of the conduit pipes should be protected from the rainwater/termites/insect's ingress by using appropriate sealant (Foam duct sealant). Cable Tie for outdoor application should be UV resistant. UPVC long "L-bend" pipes to be used wherever the cables pass through sharp edges/roof edges/angles in the wall.

AC cables entering the inverter from the grid input box, and all cables running from inverter up to the main distribution board should be provided with UPVC conduit pipe protection as well.

UPVC conduit pipes of 19 mm by diameter should be used. UPVC long-L-bends of 19 mm diameter should be used at the corners, edges. UPVC 2-way/3-way junction boxes should be used at regular spacing for maintenance purposes. The brands used here should be **ISI** certified.

NOTE:

- Cables should not be left open and should be covered through conduit pipes.
- For DC connections use only DC cables and same for AC connections use only AC cables and do not interchange or mixed.
- Ordinary PVC conduit pipes, bends and junction boxes are not allowed in the installation/to protect the DC & AC cables.

11. CHANGE-OVER SWITCHES:

- Knife-type, metal case changeover switches should be used
- Plastic case changeover switches should not be used.
- Changeover switches as per the B.O.M specifications should be used.
- Labeling of the entry & exit points of cables should be clearly marked.
- The lever position at the changeover switch for “Solar” - “Off” - “Grid” should be clearly marked with permanent marker/labels.
- Metal case should be provided with earthing protection.

12. Remote Monitoring / Data Acquisition System:

- Data acquisition system for the entire Solar System.
- Cloud based and local monitoring.
- Data logging provision for plant monitoring, time and date stamped system data logs for analysis with the high quality, suitable PC, metering and instrumentation for display of systems parameters and status indication to be provided.
- The following parameters should be accessible via the operating interface in the real time separately for solar plant:

RMS Parameters List			
Sl.No	Name of the Components	Name of the Parameters	Unit
1	Solar Panel	Solar Panel Voltage	V
		Solar Panel Current	A
		Actual Solar Generation	kW
		Today's and Cumulative Solar Generation	kWh
2	Battery	Battery Voltage	V
		Battery Charging Current	A
		Battery Charging Power	kW
		Today's and Cumulative Battery Charging Energy	kWh

		Battery Discharge Current	A
		Battery Discharge Power	kW
		Today's and Cumulative Battery Discharge Energy	kWh
		Battery State of Charge	%
3	Inverter	Inverter Output Voltage	V
		Inverter Output Current	A
		Inverter Output Power	kW
		Today's and Cumulative Inverter Output Energy	kWh
4	Grid	Grid Input to Inverter Voltage	V
		Grid Input to Inverter Current	A
		Grid Input to Inverter Active Power	kW
		Today's and Cumulative Grid Input to Inverter Energy	kWh

13. PLAQUES, SLD, SIGN BOARDS, BOM & LOAD DETAILS:

Foam Plaques:

- “DOs & DON'Ts” practices for panel, battery and P.C.U handling/routine maintenance tips
- should be pasted at the battery-inverter room
- The size of the plaque should be of A4 size for each component i.e panel, battery & P.C.U maintenance. All the three plaques should then be made as one unit for better geometry of appearance and application over the wall.
- The plaque should carry the contact details of the vendor incharge of the projects, with their office address and customer care contact details. It is suggested to also have alternate contact details included in it for better reach out.
- The plaque should be of the dimensions specified in the BOM
- The plaque should be placed at an average height of 5 feet above the ground at the entrance of the battery-inverter room and should be easily readable.
- Both local language and English should be incorporated in description of details in the plaque
- Strong adhesive (Double sided glue tape) along with washer-screw-wall plugs, should be used to keep the plaques firmly stuck to the wall

Metal plaques:

- The plaques should be placed at the entrance of the main building or at the reception counters making them easily noticeable for the visitors at the School
- The plaque should be placed at a height of 6-feet from the floor and mounted firmly over the wall using self-tapping screws and plastic reinforcement

SLD of PV system:

- A single line diagram of the entire solar PV system components installed and the way they are interconnected at the School should be clearly printed along with their electrical specifications mentioned for each component.
- The size of the SLD board should be as per the BOM specifications as it varies for different types of Schools
- The Sunboard material used to draw the SLD should be a minimum of 3-mm thick and should be glued to the wall firmly along with washer-screw-wall plugs, should be used to keep the plaques firmly stuck to the wall
- The SLD board should be placed in the same room as that of the battery-inverter set-up, and depending upon the room condition the SLD board should be placed such that it gets maximum visibility

Note:

SELCO Foundation will provide the content for SLD.

- **Sign boards:**
 - A caution sign board mentioning prohibition of smoking and open flames should be placed at the entrance of the battery-PCU room.
 - High voltage & Danger symbol to be depicted at the entrance of the room
 - Fire extinguisher operating procedure (PASS sequence) during emergency
- **Earth pits:**
 - Each earth pit should be given a labelling to identify the systems they are connected to.
 - The size of the sign board should be of A5 size and should be supported by a GI pole of 2.5 feet tall (1.5 feet above the ground), of 2 mm thickness and of 120-micron galvanizing thickness.
 - The sign board should have the details
- **Earth pit number**
 - Earth pit connected to
 - Ohmic value of the earth pit
 - Tested date

14. SYSTEM COMPLETION-HANDOVER REPORTS:

Once the installation is complete, the system functionality should be verified, and the instantaneous electrical parameters should be recorded and should be mentioned in the report and the same should be submitted to the SELCO foundation.

- The format sequence to record the parameters should be collected from SELCO foundation.
- All the components used in the installation process, their specifications, the quantity used, grand total should be clearly specified.
- Close-up pictures of the main components of solar PV set-up with GPS coordinates clicked at respective sites should be submitted along with the completion report and should be in the order as follows:
 - Solar PV arrays
 - A.J.B

- Battery bank
- P.C.U set-up
- ACDB
- Combiner box
- Earth pits
- Lightning arrester
- Change-over switches
- Cable management (outdoor & indoor)
- Foam plaques
- Metal plaques
- SLD

16. TOOLS & TACKLES AND SPARES:

After completion of installation & commissioning of the power plant, necessary tools & tackles shall be maintained by the successful bidder for maintenance purposes at the local service center.

17. SAFETY MEASURES:

The bidder shall take entire responsibility for electrical safety of the installation(s) and follow all the safety rules & regulations applicable as per Electricity Act, 2003 and CEA guidelines etc.

The work is to be done in a Health Centre that will be in service. During installation, care shall be taken to ensure no hindrance is caused to patients and medical professionals in the building while they will be on their work.

18. OPERATION AND MAINTENANCE MANUAL:

An operation, instruction and maintenance manual in English and/or local language should be provided along with the solar system. The following minimum details must be provided in the manual:

- Basic principles of photovoltaics.
- A block diagram on Solar PV System - Showing interconnection of its components viz PV modules, batteries, inverters & Charge controls and loads.
- A small write up on expected performance of the SPV systems.
- A list of the critical loads (luminaries and medical equipment) that are to be connected to the solar PV system.
- A separate list of heavy loads which are never to be connected to the system.
- A list containing specification details of panels, batteries, P.C.U., showing type of the model used, model number, voltage & current capacity
- A list of total numbers of items (Solar panels, battery, inverter, earthing pits, lightning arresters, luminaries, fans) that are provided to the School.
- Significance of audio and visual indicators of the solar PV system.
- A SLD of the system installed.
- Clear instructions on regular maintenance and troubleshooting of the solar PV System.
- A list of DOs and DON'Ts practices while handling the solar PV system.
- Name, address and contact details of the customer care service/service provider for repair complaints and scheduled & unscheduled maintenance services.

19. ANNUAL MAINTENANCE:

- Two Scheduled visits per year with 6 months of interval gap should be done.
- Schedule visits should consist of basic maintenance of the system:
- Cleaning of panels and inspecting their condition and performance
- Cleaning of batteries & inspect the battery performance.
- Inspecting inverter performance.
- Verifying the battery-inverter room has proper ventilation maintained
- Verifying the DOs & DON'TS plaques, SLD & load details sheets are present in the battery room
- Verifying the connectivity & condition of earth pits, ensure the resistance of the earth pits is below 5 Ohms
- Ensuring the lightning arrester set-up is intact
- Checking and verifying system performance with prescribed format provided by SELCO Foundation.

ANNEXURE 3: LIST OF SCHOOLS

Indicative count of Schools is as follows. However, the sites are subject to change further to the site survey. SELCO Foundation will have the complete right on the selection of Schools across state of Maharashtra and Karnataka.

Sr. No	Schools name	Trust Name	LOCATION	Proposed system	Phase
1	New English School	Jai Shivrai Pratishthan	Maan	3 Kw	Single Phase
2	Mahatma Phule vidyalaya	Mahatma Phule shikshan mandal	Lavale	5 KW	Single Phase
3	New English School & jr clg	Janta shikan sanstha	Hinjewadi	3 Kw	Single Phase
4	New English school	Pune shikshan mandal	Gothawade	3 Kw	Single Phase
5	Shri shivaji vidya mandir and jr clg	Janta shikan sanstha	Aundh	5 kw	Three Phase
6	New primary school	Janta shikan sanstha	New Sangvi	5 kw	Three Phase
7	swami vivekanand vidyalay BT Patil Jr clg	Janta shikan sanstha	Dapodi	5 kw	Three Phase
8	Indrayani Vidya mandir	Trust	Talegaon	5 kw	Single Phase
9	Chetan Dattaji Gaikwad Vidyalaya	Namdevrao Mohol Vidya Pratishthan	Bavdhan	3 Kw	Single Phase
10	Narsinh Vidyalaya Tathawade Tal. mulshi	Namdevrao Mohol Vidya Pratishthan	Tathawade	3 Kw	Single Phase
11	Z P school	Government	Nande	3kw	Single Phase
12	Z P School Rihe	Government	Rihe	2 kw	Single Phase
13	GHS Gunjuru	Government	Bangalore Karnataka	5 kw	Single Phase
14	GHS RAMMURTHYNAGARA	Government	Bangalore Karnataka	3KW	Single Phase
15	GHS RAMAGONDANAHALLI	Government	Bangalore Karnataka	5KW	Three Phase
16	GHPS mahadevapura	Government	Bangalore Karnataka	5Kw	Three Phase
17	GHPS MURUGESH PALYA	Government	Bangalore Karnataka	2KW	Single Phase
18	KPS VISHWANATHAPURA PU COLLEGE	Government	Bangalore Karnataka	5Kw	Three Phase
19	KPS VISHWANATHAPURA HIGH SCHOOL	Government	Bangalore Karnataka	2kw	Single Phase
20	GHPS NARAYANAPURA	Government	Bangalore Karnataka	2kw	Single Phase
21	KPS KAGGALIPURA	Government	Bangalore Karnataka	5kw	Single Phase
22	GHPS NARSIPURA (VIDYARANYAPURA)	Government	Bangalore Karnataka	5kw	Single Phase
23	GTHPS ANANDAPURA	Government	Bangalore Karnataka	1KW	Single Phase
24	GLPS SEETHARAMA PALYA	Government	Bangalore Karnataka	1KW	Single Phase
25	Glps singayyanapalya	Government	Bangalore Karnataka	1kw	Single Phase
26	GIPS JUNNASANDRA	Government	Bangalore Karnataka	1Kw	Single Phase
27	GLPS HALEHALLI	Government	Bangalore Karnataka	1kw	Single Phase
28	GLPS HALANAYAKANAHALLI	Government	Bangalore Karnataka	1kw	Single Phase

ANNEXURE 4: SELECTION OF COMPONENT

Note : Please fill the blanks and do necessary changes if required

Technical Specifications

Component	Specifications	Option 1 : 1 Kwp	Option 2 : 2 Kwp	Option 3 : 3 Kwp	Option 4 : 5 Kwp- Single Phase	Option 5 : 5 Kwp- Three Phase
Solar Module	Make/manufacturer					
	Type	Monoperc	Monoperc	Monoperc	Monoperc	Monoperc
	Product Warranty	> 10 Years	> 10 Years	> 10 Years	> 10 Years	> 10 Years
	Performance Warranty	>= 25 Years	>= 25 Years	>= 25 Years	>= 25 Years	>= 25 Years
	Power tolerance					
	Number of cells	144	144	144	144	144
	Power in Wp	550	550	550	550	550
	Voc(V)					
	Isc (I)					
	Vmp(V)					
	Imp(I)					
	Module Efficiency	> 20%	> 20%	> 20%	> 20%	> 20%
	Each Panel Capacity (Wp)	550	550	550	550	550
	Total Panel Quantity (Nos)	2	3	4	9	10
	Total Panel Capacity (Wp)	1100	1650	2200	4950	5500
No of Panels connected in series	1	3	2	9	5	
No of Parallel Strings	2	1	2	1	2	
Solar Battery	Make/Manufacturer					
	C rating	C10	C10	C10	C10	C10
	Type / Chemistry	VRLA	VRLA	VRLA	VRLA	VRLA
	Plate technology	Flat	Flat	Flat	Flat	Flat

	Product Warranty - Replacement	5 Years / 60 Months	5 Years / 60 Months	5 Years / 60 Months	5 Years / 60 Months	5 Years / 60 Months
	Battery Voltage	12 V	12 V	12 V	12 V	12 V
	Each Battery Capacity (Ah)	100	200	200	200	200
	Total Battery Quantity (Nos)	2	4	4	8	8
	Design capacity of battery in terms of KWh	2.4	9.6	9.6	19.2	19.2
	No of batteries connected in series					
	No of Parallel Strings					
	No of cycles @80% DOD					
	Self-Discharge rate					
	Wh efficiency	>= 80%	>= 80%	>= 80%	>= 80%	>= 80%
	Ah efficiency	>= 90%	>= 90%	>= 90%	>= 90%	>= 90%
PCU	Make/manufacturer					
	Product Warranty	5 Years	5 Years	5 Years	5 Years	5 Years
	Mounting Type	Wall Mount	Wall Mount	Wall Mount	Wall Mount	Wall Mount
	Total Harmonic Distortion (THD)					
	Inverter Capacity (kVA)	1.4	2.5	4	6	7.5
	System Voltage (Battery Input voltage)					
	Output voltage	230	230	230	230	415
	Output frequency	50 Hz	50 Hz	50 Hz	50 Hz	50 Hz
	Compatible with Alternators / Generators					
	Type of charge controller (DC-DC converter)	MPPT	MPPT	MPPT	MPPT	MPPT
	MOSFET / IGBT Based					
	Efficiency of charge controller(DC-DC converter)	> 90%	> 90%	> 90%	> 90%	> 90%
	Maximum input voltage range(Voc)					
	Input MPPT range (Vmpp)					

	Inverter minimum response time	< 20 mS	< 20 mS	< 20 mS	< 20 mS	< 20 mS
	RMS data type	RS 485	RS 485	RS 485	RS 485	RS 485
	No Load Power when Inverter is ON condition					
	Power Factor	0.8	0.8	0.8	0.8	0.8
	Inverter Efficiency	> 85%	> 85%	> 85%	> 85%	> 85%
	Cooling Mechanism (Active / Forced)					
	Operating humidity					
	Over voltage protection	Yes	Yes	Yes	Yes	Yes
	Under voltage protection	Yes	Yes	Yes	Yes	Yes
	Overload protection	Yes	Yes	Yes	Yes	Yes
	Over Temperature protection	Yes	Yes	Yes	Yes	Yes
	Battery reverse polarity protection	Yes	Yes	Yes	Yes	Yes
Panel reverse polarity protection	Yes	Yes	Yes	Yes	Yes	
DC Cables - Solar - PV1-F	Make					
	Type					
	Conductor Material	COPPER	COPPER	COPPER	COPPER	COPPER
	Insulation Material	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED
	Voltage Rating	1200	1200	1200	1200	1200
	Operating Temperature range					
DC Cables - (AJB - Inverter) & Battery	Make					
	Type					
	Conductor Material	COPPER	COPPER	COPPER	COPPER	COPPER
	Insulation Material	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED
	Voltage Rating	1000	1000	1000	1000	1000
Operating Temperature range						
AC Cables	Make					
	Type					

	Conductor Material	COPPER	COPPER	COPPER	COPPER	COPPER
	Insulation Material	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED
	Voltage Rating	1000	1000	1000	1000	1000
	Operating Temperature range					
Cables - Earthing	Make					
	Type					
	Conductor Material	COPPER	COPPER	COPPER	COPPER	COPPER
	Insulation Material	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED	PVC INSULATED
	Voltage Rating					
	Operating Temperature range					
Cables/Down Conductor for Lightning Arrestor	Material	GALVANIZED IRON	GALVANIZED IRON	GALVANIZED IRON	GALVANIZED IRON	GALVANIZED IRON
	Type	Insulated (Outdoor)	Insulated (Outdoor)	Insulated (Outdoor)	Insulated (Outdoor)	Insulated (Outdoor)
	Size	25 x 3 mm	25 x 3 mm	25 x 3 mm	25 x 3 mm	25 x 3 mm
Earthing Electrode	Make					
	Type	Solid Steel Electrode with Bonded Copper	Solid Steel Electrode with Bonded Copper	Solid Steel Electrode with Bonded Copper	Solid Steel Electrode with Bonded Copper	Solid Steel Electrode with Bonded Copper
	Bonding Thickness	250 microns	250 microns	250 microns	250 microns	250 microns
	Diameter	16 mm	16 mm	16 mm	16 mm	16 mm
	Length	2000 mm	2000 mm	2000 mm	2000 mm	2000 mm
	Backfill compound (Clay / Graphite / Bentonite)					
Lightning Arrestor	Make					
	Type	Solid Aluminium Alloy	Solid Aluminium Alloy	Solid Aluminium Alloy	Solid Aluminium Alloy	Solid Aluminium Alloy
	Diameter	15 mm	15 mm	15 mm	15 mm	15 mm
	Length	2000 mm	2000 mm	2000 mm	2000 mm	2000 mm
	Elevation Pole Diameter	40 mm	40 mm	40 mm	40 mm	40 mm
	Elevation Pole Height	3000 mm	3000 mm	3000 mm	3000 mm	3000 mm
	Supporting Wires for pole	Yes	Yes	Yes	Yes	Yes
	Double Pole MCB Make					
	Double Pole MCB Rating	16 A, 230 Vac	16 A, 230 Vac	32 A, 230 Vac	32 A, 230 Vac	16 A, 415 Vac

ACDB with Grid Changeover	Double Pole SPD Make					
	Double Pole SPD Rating with Indicators	320 Vac, Type 2, 40 kA	320 Vac, Type 2, 40 kA	320 Vac, Type 2, 40 kA	320 Vac, Type 2, 40 kA	320 Vac, Type 2, 40 kA
	Changeover Switch Make					
	Changeover Switch Type					
	Changeover Switch Rating					
Array Junction Box	String Configuration	2 IN 1 OUT	1 IN 1 OUT	2 IN 1 OUT	1 IN 1 OUT	2 IN 1 OUT
	Inline Fuse Make					
	Inline Fuse with bracket: Rating (+ve side)	20 A	20 A	20 A	20 A	20 A
	No of Fuse	2	1	2	1	2
	Double Pole MCB Make					
	Double Pole MCB Rating	40 A, 500 Vdc	20 A, 500 Vdc	40 A, 500 Vdc	20 A, 800 Vdc	40 A, 500 Vdc
	Double Pole SPD Make					
Double Pole SPD Rating with Indicators	100 Vdc, Type 2, 40 kA	250 Vdc, Type 2, 40 kA	180 Vdc, Type 2, 40 kA	600 Vdc, Type 2, 40 kA	300 Vdc, Type 2, 40 kA	

ANNEXURE 5 - DETAILS OF THE ORGANIZATION

(Enclose separate sheets as necessary and in this checklist indicate yes or no)

1	Name and address of the Bidder (With pin code)	
2	Year of starting the organization	
3	Registration number (photocopy of registration certificate or any other relevant document to be enclosed)	
4	Name and Contact number of the Proprietor or Point of Contact	
5	Status of Supplier- Proprietorship / Partnership/ Pvt Ltd / Limited/others	
6	GSTIN (Copies of certificates to be enclosed)	
7	PAN No. from Income Tax Dept. (Copies of certificates to be enclosed)	
8	Documents to prove last financial year business of Rs 01 Crore.	
9	Experience of Supplier/supplier relating to supply of solar energy-based solutions (supporting certificates to be enclosed)	
10	Particulars of Physical Infrastructure and total strength of staff available in the organization.	
11	Bidders Bank details	
12	Evidence of existence (GST Registration) of local office in the State of Maharashtra and Karnataka.	

Signature of the bidder and address with seal

Date:

ANNEXURE 6 – CONFIRMATION ON ENCLOSURES

Sl.No.	Description	Whether the Document is enclosed or not	Page No. From and to
1	Details of Organization as per Annexure 5	YES/NO	
2	Copies showing the legal status, places of registration and principal place of business of the firm	YES/NO	
3	Copies of audited financial statements for the last 2 years	YES/NO	
4	Copy of GST registration		
5	Copies of GST returns filed in the previous 2 financial years	YES/NO	
6	Copies of income tax returns filed in the previous 2 financial years	YES/NO	
7	Copy of PAN Card should be submitted	YES/NO	
8	Acceptance to provide service & Maintenance for 5 years	YES/NO	
9	Evidence of existence (GST Registration) of local offices in the state of Maharashtra and Karnataka	YES/NO	
10	Letter of declaration to confirm that the bidder has not been black listed by any entity or institution	YES/NO	
11	Documents to prove business of Rs. 01 crore in the previous financial year	YES/NO	
12	Project Report on 3 successful Solar Off-grid Projects with contact details of customer	YES/NO	
13	Implementation plan to complete Installation in 30 days, this should include Team Structure & Team Size (no's) and installation schedule.	YES/NO	
14	Bidders bank details	YES/NO	
15	Signed, sealed copies of Annexure 1, 2, 3, 4, 5 and 6	YES/NO	
16	Self-Declaration as per Annexure 4 for the components that will be used for the project	YES/NO	
17	Data Sheets/Brochures of PV Module, Battery & Inverters/PCU	YES/NO	

I abide by all the above terms & conditions.

SIGNATURE OF THE BIDDER and with office seal

PLACE:

DATE:

ANNEXURE 7- SCHEDULE OF INSTALLATION

Regarding Supply, installation and commissioning

Sl. No.	Scheduled activity	Within days (no. of days)	Accepted Schedule by date
1.	Supply starts after WO	10 Days	
2.	Supply ends	20 Days	
3	Installations begins	10 Days	
4.	Commissioning of all the system	30 days	

I abide by all the commitments accepted & conditions.

SIGNATURE OF THE BIDDER and with office seal

PLACE:

DATE:

ANNEXURE 8 - PRICE SCHEDULE

PARTICULARS TO BE SUBMITTED IN THE FINANCIAL BID (SECOND COVER).

PRICE SCHEDULE FOR THE SUPPLY, INSTALLATION, COMMISSIONING & COMPREHENSIVE MAINTENANCE FOR 5 YEAR OF OFF-GRID SOLAR ENERGY SOLUTIONS FOR 28 HIGHER PRIMARY SCHOOLS ACROSS STATE OF MAHARASHTRA AND KARNTAKA DURING THE YEAR 2024-2025.

Rates quoted by the bidder:

- a. The rates should be mentioned item wise clearly both in words and figures
- b. Rates should be inclusive of GST however specified in the below given cell.
- c. Rates should be inclusive of AMC for 5 years.
- d. Data Sheets/Brochures of PV Module, Battery & Inverters and charge controllers have to be submitted.
- e. Rates should include transportation, installation cost for supply of solution and any other cost in the region of operation of the Organizations.

SI No	System	Quantity	Price in Rs. for solar Component (per unit)	Price in Rs for AMC – 5 Years (per unit)	GST @12% for Solar Component (70%)	GST @18% for Solar Component (30%) + AMC (100%)	Total Cost Per Unit	GRAND TOTAL
1	Solar System - 1 kWp	6						
2	Solar System – 2 kWp	4						
3	Solar System – 3 kWp	7						
4	Solar System – 5 kWp Single Phase	6						
5	Solar System – 5 kWp Three Phase	5						
Grand Total (Total of Solar System)								

In words :Rupees _____

CONDITIONS:

If our tender is accepted, we hereby undertake to abide as per the stipulated Terms and Conditions to supplier and supply, installation and maintenance of solar energy-based solutions.

We agree to abide by this tender and if the work is awarded to us, in executing the above contract we will strictly observe the laws against fraud and corruption in force in India namely "Prevention of corruption act 1988".

We understand that you are not bound to determine the price based on the lowest offer that Foundation may receive.

We accept that all disputes between parties will be adjudicated by a competent court in Bangalore, India.

I, _____ (Name of signatory) on behalf of the bidder _____ (Name of the bidder), hereby certify that I have noted the technical specifications of solutions mentioned in Annexure 1, and the technical specifications for components mentioned in Annexure 2 and the prices quoted above are as per the details specified and in compliance with Annexure 1 and 2.

Dated this..... day of.....2024

Signature (Name and Address of the Tender with seal) (In the capacity of.....)

Duly authorized to sign the Tender for and on behalf of _____